

ADRF-BBL-X Series

(UL 2524 Certified 12V / 24V / 48V Battery Backup Solutions for ADRF Public Safety Repeaters / DAS)



Product Features

- Tested and approved under UL 2524, Second Edition by MET Laboratories, Inc. with PSR-78-9533-X, PSR-78-9537-X, and PSR-VU-9537-X
- Includes single cable between battery and DAS / repeater
- NFPA 2016 compliant including 12-hour runtime and battery disconnect alarm
- Increase runtime by adding unit using parallel cable (ADRF-BBX-CBL-21P)
- Increase voltage by adding unit using series cable (ADRF-BBX-CBL-21S)
- Available in 12V, 24V, 48V solutions
- Optional wall mount kit available (ADRF-BBL-X-WMK)

Electrical Specifications

	ADRF-BBL-X-12	ADRF-BBL-X-24	ADRF-BBL-X-24 (x2)
Operating Voltage	12V	24V	48V
Battery Capacity	240Ah	120Ah	120Ah
Configuration	Parallel	Series	Series
Battery Type	Lead Acid	Lead Acid	Lead Acid

Mechanical Specifications

	ADRF-BBL-X-12	ADRF-BBL-X-24	ADRF-BBL-X-24 (x2)
Dimension	17.34 x 17.34 x 12.14 in.	17.34 x 17.34 x 12.14 in.	17.34 x 17.34 x 12.14 in. (x2)
Weight (Enclosure)	42.1 lbs.	42.1 lbs.	42.1 lbs. (x 2)
Weight (Batteries)	70.0 lbs. (x 2)	70.0 lbs. (x 2)	70.0 lbs. (x 4)
Weather Resistance	NEMA 4	NEMA 4	NEMA 4
Cooling	Air Convection	Air Convection	Air Convection
Mounting Type	Ground (with wheel locks) or Wall (optional brackets)		

Battery Runtime

	ADRF-BBL-X-12	ADRF-BBL-X-24	ADRF-BBL-X-24 (x2)
ADXV PS HE (for 4 RU / 8 RU)	63.8 / 43.4 hours	-	-
ADXV-R-3378P-N4X	-	61.2 hours	-
ADXV-R-25VU-N4X	-	55.8 hours	-
FiRe-78-4 (single/dual band)	-	32.5 / 30.2 hours	-
FiRe-78-4 + FiRe-AAI (single/dual band)	-	30.3 / 28.7 hours	-
PSR-78-9533-X (single / dual band)	-	28.6 / 22.6 hours	-
PSR-78-9533-X (dual band @ 1W)	-	24.4 hours	-
PSR-78-9537-X (single / dual band)	-	21.1 / 14.5 hours	-
PSR-VU-9537-X (VHF / UHF)	-	-	34.9 / 33.9 hours

Web www.adrftech.com

Tel +1 818.840.8131 **Fax** +1 818.840.8138

Technical/Customer Support +1 800.313.9345

3116 West Vanowen Street Burbank, CA 91505

Copyright © 2021 Advanced RF Technologies, Inc. All rights reserved. ADRF-BBL-X / October 2021

